

Certificate

Certified Passive House Component

for cool, temperate climates; valid until 31.12.2014

Category: **Window Frame**
 Manufacturer: **Zola Windows**
80487 Steamboat Springs, USA - Color
 Product name: **ZNC**

This certificate was awarded based on the following criteria:

Given a U_g value of $0.70 \text{ W}/(\text{m}^2\text{K})$ and a window size of 1.23 m by 1.48 m ,

$$U_w = 0.8 \text{ W}/(\text{m}^2\text{K}) \leq 0.80 \text{ W}/(\text{m}^2\text{K})$$

Taking into account the installation based thermal bridges and provided that the installation is, with regard to the thermal bridges, equal or better than shown in the data sheet, the window meets the following criterion.


$$U_{w, \text{installed}} \leq 0.85 \text{ W}/(\text{m}^2\text{K})$$

Thermal data

	U_f -value [W/(m ² K)]	Width [mm]	Ψ_g [W/(mK)]	$f_{Rsi=0.25}$ [-]
Spacer			SuperSpacer Tri-Seal Bu	
Bottom	0.81	113	0.027	0.73
Side/top	0.78	113	0.030	

*Spacers of lower thermal quality, especially those made of aluminium, lead to significantly higher thermal losses and lower temperature factors.

For further information, please see the data sheet



Passive House Efficiency Class

phA
advanced component

phB
basic component

phC
certifiable component

not suitable for Passive Houses



ph B

CERTIFIED COMPONENT

Passive House Institute