

# AON SPRINKLER CERTIFICATION



## FORM 10

Aon File Reference: 2.23



### LISTING CERTIFICATE – SPRINKLER SYSTEM EQUIPMENT

As per section 114 of NZS 4541:2007 and NZS4515:2009 Appendix G

This is to confirm that, on the basis of the information supplied in the application for listing of the equipment dated December 2012, this organisation, as the nominated Sprinkler System Certifier considers that the appropriate requirements of NZS 4541:2007 and NZS4515:2009 have been adequately met with respect to the item described below, for use under the conditions set out on this certificate.

**Item Hose Supplies Hose Master Model V and U Seismic Connectors**

For use as **Seismic Joint Assemblies**

Certificate number **M-29**

Effective from **27 May 2013**

Manufacturer / Supplier **Hose Supplies**

Make **Hose Master**

Model **HSSVC and HSSUC Seismic Connectors**

Reference information

Range limitations

Restrictions and warnings

Special conditions

**Hose lengths to be calculated by Hose Supplies for specific movement required**

**Unbraided hose not suitable due to maximum working pressure requirements**

Signed

Date

*27 May 2013*

Name *Chris Mak*

Designation *IANZ Approved Signatory*