## **East Gippsland Shire Council**



273 Main Street (PO Box 1618) Bairnsdale VIC 3875 Website www.eastqippsland.vic.qov.au Email feedback@eqipps.vic.gov.au Follow us on Twitter @egsc



Telephone: (03) 5153 9500 Fax: (03) 5153 9576 National Relay Service: 133 677 ABN: 81 957 967 765



## Fire Plug Inspection and Fault Report

Town									
							Council	o only	
Fault No	Street Name	I	louse No	Fault Code	Insp	Date	Council us Authority	CRMs No	
1	Smith Street		1	P	8/5/2		EGS	24680	
				<u> </u>	1				
Fault No	Street Name H		House No	Fault Code	Insp	Date	Authority	CRMs No	
1									
2	<u> </u>								
3 4	+								
5	+								
6	+								
7									
8									
9									
10									
11									
12									
13									
14									
15									
Fault Code	)		Authority	Notes					
S - CD	Site clean-up required -Card left								
S - EGS	Site clean-up required		EGS						
Р	Marker post/box need	EGS							
С	Hydrant cap/blank cap missing		WB						
В	No box cover/hydrant cover		WB						
М	Missing or damaged marker post		EGS						
W	Marker post wrong direction		WB						
OK	Okay								
G	Hydrant plug cannot be located		WB						
R	Box or base requires resetting		WB						
D	Plug too deep for standpipe		WB						
L	Hydrant/Plug missing		WB						
1	Indicator	EGS							
0	Other		?	Provide more information on back page					
CFA Country Fire Authority EGSC Ea			ast Gippsla	st Gippsland Shire Council WE			East Gippsland Water		
Signature:									
Name: Date/							1		

Return form to Emergency Management Co Ordinator East Gippsland Shire

## **East Gippsland Shire Council**



273 Main Street (PO Box 1618) Bairnsdale VIC 3875 Website www.eastqippsland.vic.qov.au Email feedback@egipps.vic.gov.au Follow us on Twitter @egsc





## Additional Faults Information

Example

Fault No	Address	Information			
6	34 Smith	Access issue due to fence erected over hydrant			
Fault No	Address	Information			
Notes					