

OPERATION AND MAINTENANCE PROCEDURES



Operation and Maintenance Procedures

Our products are designed to require minimum or no maintenance. The recessed cavity boxes and in-line sleeves contain only one or two moving parts (gravity dampers) depending on the model.

Annual Inspections and Maintenance:

An annual visual inspection of the dryer, bathroom and residential kitchen exhaust termination box or sleeve is recommended.

Dryer Applications:

Inspection of exhaust boxes or in-line sleeves used in conjunction with dryer exhaust may require more frequent inspection due to frequency of use.

Required:

Removal of all visible lint in and around the box or sleeve, particularly around the damper frame assembly and gravity damper.

Recommended:

Confirm that the duct between the dryer and the termination box is free of lint build up.

X Vent Box

8022 Providence Rd. Suite: 500-145
Charlotte, NC 28277

customerservice@xventbox.com