



## UN APPROVED IBC INSPECTION CERTIFICATE

Test carried out at: CA Roofing C/O Winvic, Symmetry park, New Co-op Facility,  
Biggleswade SG18 8QB

### Product Details: 2000 Litre Fuelstore

Approval No:	3/AZ/03/18GBFP/4907/0/2560
Manufacturer:	Fuel Proof
Serial No:	27558
Year of Manufacture:	2018
Nominal Capacity:	2000 Litre
Date of Initial Test:	03-18
Date of Latest Periodic Test:	09-20
Certificate expiry date:	March 2023

### Comments

Pressure test on inner cylinder ok:	YES
Visually examine the bowser internally and externally, in good condition:	YES
Visually examine interconnecting pipework and fittings, in good condition:	YES
Visually examine pumping gear, in good condition:	YES
Visually examine mounting bolts, in good condition:	YES

Inspector:

Signature:

Neil Wilson.

Fuel Proof Limited

Date: September 14, 2020

**Fuel Proof Ltd**

Registered office: Middleton Business Park, Middleton Road, Heysham, Lancashire, LA3 3FH  
Company registration number 3991145