



UN APPROVED IBC INSPECTION CERTIFICATE

Test carried out at: United Power Access, Head Office, Lymm Service Station,
Warrington WA13 0SP

Product Details: 2000 Litre

Approval No:	31A/Z/03/18/GBFuelProof/4907/0/2560
Manufacturer:	Fuel Proof
Serial No:	27559
Year of Manufacture:	2018
Nominal Capacity:	2000 Litre
Date of Initial Test:	March 2018
Date of Latest Periodic Test:	September 2020
Certificate expiry date:	March 2023

Comments

Pressure test on inner cylinder ok:	YES
Visually examine the bowser internally and externally, in good condition:	YES
Visually examine interconnecting pipework and fittings, in good condition:	YES
Visually examine pumping gear, in good condition:	YES
Visually examine mounting bolts, in good condition:	YES

Inspector:

Signature:

Neil Wilson.

Fuel Proof Limited

Date: September 22, 2020

Fuel Proof Ltd

Registered office: Middleton Business Park, Middleton Road, Heysham, Lancashire, LA3 3FH
Company registration number 3991145