

BT10900-03



UN APPROVED IBC INSPECTION CERTIFICATE

Test carried out at: CA GROUP, DSV TAMWORTH, C/O WINVIC, PLOT 6, STRETTON EN
LE FIELD, LEICESTER, JUNCTION 11 M42, DE12 811

Product Details: 900 FC

Approval No:	31A/Z/01/17/GB Fuelproof-5952/2441/1224
Manufacturer:	Fuel Proof
Serial No:	22151-11
Year of Manufacture:	2017
Nominal Capacity:	900 Litres
Date of Initial Test:	January 2017
Date of Latest Periodic Test:	September 2021
Certificate expiry date:	March 2023

Comments

Pressure test on inner cylinder ok:	YES
Visually examine the bowser internally and externally, in good condition:	YES
Visually examine interconnecting pipework and fittings, in good condition:	YES
Visually examine pumping gear, in good condition:	YES
Visually examine mounting bolts, in good condition:	YES

Inspector:

Signature:

Neil Wilson.

Fuel Proof Limited

Date: September 10, 2021

Fuel Proof Ltd

Registered office: Middleton Business Park, Middleton Road, Heysham, Lancashire, LA3 3FH
Company registration number 3991145