

BT10900-04



## UN APPROVED IBC INSPECTION CERTIFICATE

Test carried out at: GEOROF LTD, C/O MITCHELL DESIGN AND CONSTRUCTION,  
BEACON HILL ROAD, GU528DY

### Product Details: 900 FC

Approval No:	31A/Z/01/17/GB Fuelproof-5952/2441/1224
Manufacturer:	Fuel Proof
Serial No:	22151/7
Year of Manufacture:	2017
Nominal Capacity:	900 Litres
Date of Initial Test:	January 2017
Date of Latest Periodic Test:	September 2021
Certificate expiry date:	March 2023

### Comments

Pressure test on inner cylinder ok:	YES
Visually examine the bowser internally and externally, in good condition:	YES
Visually examine interconnecting pipework and fittings, in good condition:	YES
Visually examine pumping gear, in good condition:	YES
Visually examine mounting bolts, in good condition:	YES

Inspector:

Signature:

Neil Wilson.

A handwritten signature in black ink, appearing to read "Neil Wilson", written over a horizontal line.

Fuel Proof Limited

Date: September 10, 2021

**Fuel Proof Ltd**

Registered office: Middleton Business Park, Middleton Road, Heysham, Lancashire, LA3 3FH  
Company registration number 3991145